



Australian Building Codes Board  
**WATERMARK CERTIFICATION SCHEME**  
**SCHEDULE OF EXCLUDED PRODUCTS**

**This document was adopted 1 August 2017  
and replaced the WaterMark List of Exempt Materials and Products**

Product	Application	Reference
ACCESS COVERS AND FRAMES		AS 3996
<b>APPLIANCES AND FIXTURES</b>		
Air conditioner (evaporative cooler)		
Bain marie		
Dental equipment		
<b>WATER-USING APPLIANCES</b>		
Photographic processor		
Clothes washing machine	Domestic	AS/NZS 60335.1
Dish washing machine	Domestic	AS/NZS 60335.1
Commercial ice maker	Ice not intended for human consumption.	WMTS.105
Vacuum cleaner		
<b>FITTINGS – PIPES</b>		
Class 1 thermoplastic co-extruded smooth bore hoses for air-conditioning split system	Pressure	*
Manual operated flow limiting device for showers	Non-pressure	*
Tap outlet diverter (end of line)	Non-pressure	*
<b>OTHER PRODUCTS</b>		
Basin		Outlets require certification (See WMTS.040)
Bath		Outlets require certification (See WMTS.040)
Sink		Outlets require certification (See WMTS.040)
Laundry trough		Outlets require certification (See WMTS.040)
Water treatment additives		Not required to be certified
Automatic electronic drainage monitoring system	Non-pressure	*
Hot water safe tray		*
Wind powered sewer fan (whirly bird)		*
Fire hydrant		AS 2419.2
Fire protection booster valves		AS 2419.3

**Notes:**

**From 1 August 2017 this Schedule superseded the WaterMark List of Exempt Materials and Products.**

\* Evidence of suitability for installation to be accordance with Provision A2.2 (a)(ii)-(iv) and (b) of the Plumbing Code of Australia.

This schedule supersedes the previous version of the WaterMark Schedule of Excluded Products dated 21/09/2017 with updates in yellow.

Disclaimer: this document is uncontrolled when printed, the information contained within changes from time to time. You may need to consult the ABCB website to verify its currency.

Version:  
01/02/2018

Product	Application	Reference
WATER LININGS		
Linings - Water	Coatings for potable water steel tank lining.	APAS approved products (see <a href="http://www.apas.gov.au">www.apas.gov.au</a> )
Linings - Sewage	Coatings for steel and concrete in sewage works	APAS approved products (see <a href="http://www.apas.gov.au">www.apas.gov.au</a> )
Linings – Water pumps and valves	Coating systems intended for the internal lining of ferrous and non-ferrous pumps and valves used for potable water reticulation.	APAS approved products (see <a href="http://www.apas.gov.au">www.apas.gov.au</a> )

**Notes:**

**From 1 August 2017 this Schedule superseded the WaterMark List of Exempt Materials and Products.\*** Evidence of suitability for installation to be accordance with Provision A2.2 (a)(ii)-(iv) and (b) of the Plumbing Code of Australia.

*This schedule supersedes the previous version of the WaterMark Schedule of Excluded Products dated 21/09/2017 with updates in yellow. Disclaimer: this document is uncontrolled when printed, the information contained within changes from time to time. You may need to consult the ABCB website to verify its currency.*

Version:  
01/02/2018