

**WaterMark Certification Scheme**

**Risk Assessment Notification**

**2017/R15**

**Product Assessed: - Small Bore Manifolds  
for use in hot and cold water installations.**

Level 12  
SAP House  
Cnr Bunda & Akuna Streets  
Canberra ACT 2601  
GPO Box 9839  
Canberra ACT 2601 Australia  
Phone: 1300 134 631  
Email: [NCC@abcb.gov.au](mailto:NCC@abcb.gov.au)  
Web: [www.abcb.gov.au](http://www.abcb.gov.au)

**Assessment**

The WaterMark Administration advises it has reviewed a risk assessment submitted for the above mentioned product.

**Outcome**

In accordance with the WaterMark Scheme Rules, any new, or innovative material, or product that is required to comply with AS/NZS 4020 requires a Level 1 Certification. Therefore, the Small Bore Manifold assessed will require a Level 1 Certification.

**Issued**

23 March 2017.

- END -