

WaterMark Certification Scheme

Risk Assessment Notification

2017/R26

Product Assessed: - Packaged Pump Station

Level 12, 224 Bunda Street
Canberra ACT 2600
GPO Box 2013
CANBERRA ACT 2601 Australia
Phone: 1300 134 631
Email: NCC@abcb.gov.au
Web: www.abcb.gov.au

Assessment

The WaterMark Administration advises it has reviewed a risk assessment submitted for the above mentioned product. The product is a prefabricated packaged pumping station. The Product is utilised for pumping waste when it is not practical to gravitate to the Sewerage System.

The WaterMark Administration verifies that the risk assessment for the prefabricated packaged pumping station has identified risks requiring mitigation through the WaterMark Certification Scheme.

Outcome

The Risk Assessment identified the overall risk rating being medium for the nominated health and safety consequences incidences. In accordance with the *Manual for the WaterMark Certification Scheme, Appendix 3, Table D*, any product with an overall risk rating of medium requires WaterMark Certification.

Approved WaterMark Conformity Assessment Bodies will now need to evaluate these products to the most applicable specification. If the identified risks are unable to be satisfactorily addressed through an existing Specification, then a new, or amended Specification shall be proposed. A submission to the ABCB shall be undertaken in accordance with the *Manual for the WaterMark Certification Scheme, Appendix 4, Protocol for Developing Product Specifications*.

Issued

30 July 2018.

- END -