

WaterMark Certification Scheme

Risk Assessment Notification

2020/R48

Product Assessed: - Food Waste Digester

Level 12, 224 Bunda Street
Canberra ACT 2600
GPO Box 2013
CANBERRA ACT 2601 Australia
Phone: 1300 134 631
Email: NCC@abcb.gov.au
Web: www.abcb.gov.au

Assessment

The WaterMark Administration advises it has reviewed a risk assessment submitted for the above mentioned product. The function of this product is to break down biodegradable material using microorganisms in the presence of oxygen and to output as grey water.

The WaterMark Administration verifies that the risk assessment for the food waste digester has identified risks requiring mitigation through the WaterMark Certification Scheme.

Outcome

The Risk Assessment identified the overall risk rating being medium for the nominated health and safety, economic or water wastage consequences incidences. In accordance with the *Manual for the WaterMark Certification Scheme, Appendix 3, Table D*, any product with an overall risk rating of medium requires WaterMark Certification.

The WaterMark Schedule of Products will now be revised to reflect the most appropriate specification for these products. Approved WaterMark Conformity Assessment Bodies will be required to evaluate these products in accordance with the Scheme Rules to the listed specification.

Issued

26 February 2020.

- END -