



WaterMark Certification Scheme

Risk Assessment Notification

2020/R62

Product Assessed: Pedicure Foot Spa

Assessment

The WaterMark Administration advises it has reviewed a risk assessment submitted for the above mentioned product.

The WaterMark Administration verifies that the risk assessment for this product has identified risks requiring mitigation through the WaterMark Certification Scheme.

Outcome

The Risk Assessment identified the overall risk rating being medium for the nominated health and safety consequences incidences. In accordance with the *Manual for the WaterMark Certification Scheme, Appendix 3, Table D*, any product with an overall risk rating of medium requires WaterMark Certification.

Approved WaterMark Conformity Assessment Bodies will now need to evaluate these products to the most applicable specification. If the identified risks are unable to be satisfactorily addressed through an existing Specification, then a new, or amended Specification shall be proposed. A submission to the ABCB shall be undertaken in accordance with the *Manual for the WaterMark Certification Scheme, Appendix 4, Protocol for Developing Product Specifications*.

Upon receipt of the proposed nominated Specification the WaterMark Administration will review and verify the proposed nomination which shall include a public consultation period as outlined in clauses 1.7.2 and 2.7.2 of the Protocol for Developing Product Specifications.

Issued

11 November 2020.